



## **ΣΥΣΤΗΜΑΤΑ ΦΙΛΤΡΑΡΙΣΜΑΤΟΣ ΠΟΣΙΜΟΥ ΝΕΡΟΥ REVERSE OSMOSIS**

### **ΣΥΝΤΗΡΗΣΗ**

Είναι σημαντικό η συντήρηση της μονάδας σας να πραγματοποιείται από έναν εξουσιοδοτημένο τεχνικό, ο οποίος θα χρησιμοποιήσει αυθεντικά εξαρτήματα αντικατάστασης και θα σας προσφέρει ένα συμβόλαιο συντήρησης και μια εγγύηση υπηρεσιών. Ο χειρισμός και η χρήση μη αυθεντικών εξαρτημάτων από μια επιχείρηση ή ένα πρόσωπο άλλο από τους διανομείς μας ακυρώνει την εγγύηση τόσο του μηχανήματος όσο και του επίσημου διανομέα.

Μερικά στοιχεία της συσκευής, όπως το προφίλτρο, τα κοκκώδη ενεργοποιημένα φίλτρα άνθρακα, η μεμβράνη αντίστροφης όσμωσης και το τελικό φίλτρο έχουν περιορισμένη ζωή και απαιτούν αντικατάσταση. Το πόσο καιρό θα διαρκέσουν θα εξαρτηθεί από το τοπικό νερό και τους ειδικούς παράγοντες, όπως η είσοδος της λάσπης, της ακραίας θολούρας, της υψηλής χλωρίωσης, της σκληρότητας, της ύπαρξης του σιδήρου, κλπ.

Συστήνεται το σύστημα να απολυμαίνεται με τον ίδιο τρόπο όπως και στο ξεκίνημα (βλέπε οδηγίες εγκατάστασης) κάθε χρόνο ή 6 μήνες. Πρέπει επίσης να απολυμανθεί όταν η μονάδα πρέπει να ανοίξει (για συντήρηση / βλάβη) ή δεν είναι σε λειτουργία για περισσότερους από έναν μήνα.

### **ΑΝΤΙΚΑΤΑΣΤΑΣΗ ΦΙΛΤΡΩΝ**

<b>ΤΥΠΟΣ ΦΙΛΤΡΟΥ</b>	<b>ΕΝΔΕΙΚΤΙΚΟΣ ΧΡΟΝΟΣ ΑΛΛΑΓΗΣ</b>
Προφίλτρο	Κάθε 6 μήνες
GAC ενεργοποιημένα φίλτρα άνθρακα (όπου υπάρχει)	Κάθε 6 μήνες (για πόσιμο νερό)
Μεμβράνη όσμωσης	Περίπου κάθε 2 χρόνια
Postfilters	Κάθε 6 μήνες
UV lamb (όπου υπάρχει)	Κάθε 12 μήνες

\* Ο χρόνος αλλαγής είναι ενδεικτικός και εξαρτάται από την ποιότητα του εισερχόμενου νερού καθώς και από την ποσότητα νερού που χρησιμοποιείται.

### **ΣΗΜΑΝΤΙΚΟ**

**ΝΑ ΓΙΝΕΤΑΙ ΑΠΟΛΥΜΑΝΣΗ ΚΑΘΕ ΦΟΡΑ ΠΟΥ ΓΙΝΕΤΑΙ ΑΛΛΑΓΗ ΦΙΛΤΡΩΝ – ΤΟΥΛΑΧΙΣΤΟ 2 ΦΟΡΕΣ ΤΟ ΧΡΟΝΟ**

[Επικοινωνήστε μαζί μας για συντήρηση, αλλαγή φίλτρων, τεχνική υποστήριξη.](#)

13A Michalakopoulou Str, 1075, P.O.Box. 29656, 1722 Nicosia, CYPRUS  
Tel: 00357-22-460240 Fax: 00357-22-480198 Web: [www.arimec.eu](http://www.arimec.eu) Email: [info@arimec.eu](mailto:info@arimec.eu)





## **SYSTEMS OF FILTERING WATER REVERSE OSMOSIS**

### **MAINTENANCE**

It is important that the maintenance of your unit is carried out by an official "advance" service, which will use original replacement parts and offer you a maintenance contract and a service guarantee. Handling of the unit or use of a non-original replacement part by a company or person other than our distributors shall invalidate both the guarantee of the "advance" unit and that of the official distributor.

Some components, such as the sediment prefilter, the granular activated carbon filters, the reverse osmosis membrane and the granular carbon post filter have a limited life and will require replacement. How long they last will depend on the local water and specific factors, such as the entry of mud, extreme turbidity, high chlorination, excess of iron, etc.

It is recommended that the system should be disinfected in the same way as for start-up every time that the yearly or half-yearly maintenance is performed. It should also be disinfected whenever the unit has to be opened or it is not operation for more than one month.

### **MAINTENANCE RECOMMENDED BY YOUR OFFICIAL ADVANCE DISTRIBUTOR**

<b>FILTER TYPE</b>	<b>SUGGESTED REPLACEMENT TIME</b>
<b>Prefilter</b>	<b>Every 6 months</b>
<b>GAC granular activated carbon filters</b>	<b>Every 6 months (for drinking water)</b>
<b>Reverse osmosis membrane</b>	<b>Around every 2 years</b>
<b>Postfilters</b>	<b>Every 6 months</b>
<b>UV lamp</b>	<b>Every 12 months</b>

\*The suggested replacement time is indicative and depends on the quality of the incoming water as well as the quantity of the used water.

### **IMPORTANT**

**A DISINFECTION MUST TAKE PLACE EVERY TIME THAT THERE IS A CHANGE OF FILTERS – AT LEAST TWICE A YEAR**

**Contact us for maintenance, change of filters, technical support.**

13A Michalakopoulou Str, 1075, P.O.Box. 29656, 1722 Nicosia, CYPRUS

Tel: 00357-22-460240 Fax: 00357-22-480198 Web: [www.arimec.eu](http://www.arimec.eu) Email: [info@arimec.eu](mailto:info@arimec.eu)

